



## Declaration of performance

Certification No.:	1330a-(c1-7)
1.Unique identification code of the product-type:	AW - BK901
2.Type, batch or serial number or any other element allowing identification of the construction product:	Batch number:---- Production site: GUTA
3.Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:	Conventional reflective beam detector for fire detection and fire alarm systems for buildings
4.Name, registered trade name or registered trade mark and contact address of the manufacturer	zhongshan guta fire equipment technology co., LTD. 4/F,#10, Xingye Rd, Huoju District Zhongshan City, Guangdong P.R. China
5.In case of the declaration of performance concerning a construction product covered by a harmonised standard:	LPCB issued the certificate of constancy of performance no:1330a on the basis of: 1) Type testing 2) Initial inspection of the manufacturing plant and of factory production control. 3) Continuous surveillance, assessment and evaluation of factory production control
6.In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:	

### 7.Declared performance

Essential characteristics	Performance	Technical specification
<b>1--sensitivity settings:</b>  -Level 1: 2.6db high sensitivity; -Level 2: 3.8 dB Medium sensitivity ; -Level 3: 5.8 dB Low sensitivity.	PASS	<b>EN54-12:2015</b>
<b>2. --Suitable for use at the following separation rangs:</b>  -Span 1: 8 to 20 meters short path(1 X mirror reflector required) -Span 2: 20 to 40 meters short path(1 X mirror reflector required)	PASS	

ASENWARE LTD

Address: 6 Prospect Way, Royal Oak Industrial Estate, Daventry, Northamptonshire, England, NN118PL

Website: [www.asenware.com](http://www.asenware.com)

Manufacturer: Zhongshan Guta Fire Equipment Technology Co., Ltd.

Address: 4F, No. 10, Xingye Rd., Huoju District, Zhongshan City, Guangdong Province, China



-Span 3: 40 to 70 meters normal path (4 X mirror reflector required) -Span 4: 70 to 100 meters long path (4 X mirror reflector required)		
---	--	--

**Responsible for making this declaration is the manufacturer.**

**Person responsible for making this declaration**

**Name: Wang Yonggang**

**Position/Title: General Manager**

**Signature:**

**Date: 2025-02-12**

ASENWARE LTD

Address: 6 Prospect Way, Royal Oak Industrial Estate, Daventry, Northamptonshire, England, NN118PL

Website: [www.asenware.com](http://www.asenware.com)

Manufacturer: Zhongshan Guta Fire Equipment Technology Co., Ltd.

Address: 4F, No. 10, Xingye Rd., Huoju District, Zhongshan City, Guangdong Province, China